## CURRENT TRANSFORM

Model 137MR

Window Diameter 5.50" REGULATORY AGENCY APPROVALS



Manufactured to meet the requirements of ANSI/IEEE C57.13. Classified by U.L. in accordance with IEC 44-1

Approved for revenue metering by Industry Canada. No. T-260

## **APPLICATION:** Relaying.

FREQUENCY:

## **INSULATION LEVEL:**

0.6 kV, BIL 10 kV full wave.

## CONTINUOUS THERMAL **CURRENT RATING FACTOR:**

See TRF at curve.

- Terminals are brass screws No.10-32 with one flatwasher and lockwasher.
- The transformer winding is arranged so that the turns are fully distributed between all taps.
- Order Mounting Bracket Kit No. 0221B01528 separately.
- Approximate weight 50 lbs.







