CURRENT TRANSFORMER

Model 141MR

Window Diameter 8.13"
REGULATORY AGENCY APPROVALS



Manufactured to meet the requirements of ANSI/IEEE C57.13.
Classified by U.L. in accordance with IEC 44—1

Approved for revenue metering by Industry Canada. No. AE-0658

APPLICATION: Relaying.

FDFOLENOV

FREQUENCY: 50-400Hz

INSULATION LEVEL:

0.6 kV, BIL 10 kV full wave. **CONTINUOUS THERMAL**

CURRENT RATING FACTOR:

See TRF at curves.

- Terminals are brass screws No.10-32 with one flatwasher and lockwasher.
- The transformer winding is arranged so that the turns are fully distributed between all taps.
- Order Mounting Bracket Kit No. 0221B00775 separately.
- Approximate weight 45 lbs.







