## CURRENT TRANSFORMER

## Model 309MR

Window Diameter 5.75"
REGULATORY AGENCY APPROVALS



Manufactured to meet the requirements of ANSI/IEEE C57.13.

Classified by U.L. in accordance with IEC 44-1

Approved for revenue metering by Industry Canada. No. AE-0661

**APPLICATION:** Relaying.


FREQUENCY:


**INSULATION LEVEL:** 0.6 kV, BIL 10 kV full wave.


CONTINUOUS THERMAL CURRENT RATING FACTOR:


See TRF at curves.

- Terminals are brass screws No.10-32 with one flatwasher and lockwasher.
- The transformer winding is arranged so that the turns are fully distributed between all taps.
- Order Mounting Bracket Kit No. 0221B01525 separately.
- Approximate weight 62 lbs.









Section 2 Rev. V 3/99